



**Contra Costa County Fire Protection District
Battalion 2 Incident Notification**

DATE: January 16, 2018

TYPE OF ALARM: Commercial Structure Fire

LOCATION: 1905 Market St– Concord

RESPONSE- 4 Engines, 2 Truck, 2 Battalion Chiefs, 1 Investigator, 1 Breathing Support, 1 Medic Ambulance

ASSISTING AGENCIES: Concord PD, PG&E

TOTAL FIRE PERSONNEL AT SCENE: 25

I arrived and reported black smoke from multiple rollup doors. There was a car on fire inside of the Lehmers GMC/Buick dealership maintenance shop. The fire had started when a worker tried to drill a fuel tank. Sprinklers kept the fire under control. CCCFPD Firefighter took hose lines interior to put the fire out. The fire was under control within twenty minutes and there was a significant amount of smoke removal needed. Damage is estimated at \$100,000. Two workers suffered minor injuries.

**Dominic Ciotola
925-383-5043 cell
Battalion II
Contra Costa County Fire Protection District**