



Contra Costa County Fire Protection District

Battalion 1 Incident Notification

Time: 14:56:33

Type of Alarm: Commercial Structure Fire

Locations: 3669 Mt. Diablo Rd., Lafayette

Response: 6-Engines, 2-Trucks, 1-Breathing Support, 1-Shift Training Captain, 3-Battalion Chiefs

Assisting Agencies: Moraga Orinda Fire, Lafayette PD, PGE, Con EMS

Total Fire Personnel at Scene: 31

Contra Costa County and Moraga Orinda Fire units responded to a commercial structure fire this afternoon in Lafayette. Engine 43 (Orinda) reported that they saw smoke while enroute to the fire. Upon arrival, the crew found smoke coming from the rear and roof of a commercial building. Engine 43 established Mt. Diablo IC. Engine and Truck 1 (Walnut Creek) arrived and went to the roof. The Station 1 crews discovered a small fire on the roof. They extinguished the fire and overhauled the area around the fire. The fire melted a plastic drain pipe that created a large amount smoke in both of the occupancies below the fire. Crews ventilated the smoke from the building and turned over the property to the owner.

No injuries were reported.

Feel free to contact me if you have any comments or questions regarding this incident.

David Watson, Acting Battalion Chief

925-808-8020

david.watson@cccfd.org